



- CX-WC14AXSMPS EQUIPMENT PACKAGE:**
- 1 CX-EMF2PS (60-40E034) - CABINET FOR MULTIFUNCTION RELAY & PS MODULE
 - 2 CM-2520/4854SE1 - "PUSH TO OPEN" AND "PUSH TO LOCK" COMBO SWITCH, WITH ENCLOSURE AND SIGN x 2
 - 3 CM-45/454SE1 - 4 1/2" ILLUMINATED PUSH PLATE WITH ENCLOSURE AND SIGN x 2
 - 4 CX-MDA - MAGNETIC DOOR CONTACT x 2
 - 5 CX-ED2079 - GRADE 2 UNIVERSAL ELECTRIC STRIKE x 2

- ADDITIONAL PARTS REQUIRED BUT NOT INCLUDED WITH THE CX-WC14AXSMPS:**
- 6 DOOR OPERATOR - SUPPLIED BY OTHERS X 2

SYSTEM OPERATION

- CX-WC14AXSMPS OPERATION:**
- THE DOORS ARE NORMALLY CLOSED AND UNLOCKED.
 - THE EXTERIOR 'PUSH TO OPEN' AURA ILLUMINATED PUSH PLATE SWITCHES OUTER RINGS ARE GREEN INDICATING THE RESTROOM IS VACANT.
 - PRESSING EITHER 'PUSH TO OPEN' SWITCH WILL OPEN THE RESPECTIVE DOOR.
 - ONCE THE DOOR IS CLOSED, PRESSING THE 'PUSH TO LOCK' ON THE COMBO PUSH PLATE SWITCH WILL LOCK THE DOOR. THE COMBO SWITCH OUTER RING WILL GLOW RED INDICATING THE DOORS ARE LOCKED.
 - THE EXTERIOR AURA™ ILLUMINATED PUSH PLATE RINGS WILL TURN RED INDICATING THE RESTROOM IS OCCUPIED.
 - PRESSING THE 'PUSH TO OPEN' ON THE COMBO SWITCH WILL OPEN THE RESPECTIVE DOOR AND RESET THE SYSTEM. AURA™ ILLUMINATED PUSH PLATE SWITCHES WILL GLOW GREEN INDICATING THE RESTROOM IS VACANT.
 - IF THE DOOR IS OPENED MANUALLY TO EXIT THE RESTROOM, THE OVERHEAD MAGNETIC CONTACT SWITCH RESETS THE SYSTEM.

- NOTE:**
1. Push Switches for the power door operator (Items 2 and 3) should be mounted with it's centre located not less than 900mm and not more than 1100mm above the finished floor and is located not less than 600mm and not more than 1500mm beyond the door swing where door opens towards the control (Item 2)
 2. Wire Must Be Stranded, Multi-Colour.

CAMDEN DOOR CONTROLS		5502 Timberlea Blvd. Mississauga, ON Canada Tel: (905) 366-3377 www.camdencontrols.com		L4W 2T7
DRAWN	NAME	DATE	TITLE:	
CHECKED	A.OLISA	MAR-20	BARRIER FREE DOOR CONTROL AND EMERGENCY	
ENG APPR.			NORMALLY UNSECURED	
MFG APPR.			(CX-WC14AXSM-PS)	
QA			SIZE	DWG. NO.
COMMENTS:			CUST.	REV
			CX-WC14AXSM-PS_Cad.DWG	
			SCALE: N/A	SHEET 1 OF 1